



Units A1 & 51 Port Talbot Business Units
 Addison Road, Port Talbot SA12 6HZ
 Tel: 01639 262001 Mob: 07588 045914
 Email: info@morganenvironmental.co.uk
 Web: www.legionellacontrolwales.co.uk

Water Hygiene Service Report

Service Report

Company Name Radyr & Morganstown Council
Site Radyr & Morganstown Community Council
Address Old Church Rooms, Park Road, Radyr, Cardiff CF15 8DF
Date Of Visit 24/01/2023
Site Contact Julie Hopkins
MEL Service Engineer Thomas Bryan, Gethyn Clarke
System/s Hot & Cold Water Systems
Task/s Carried Out TMV Service, Legionella Monitoring Service
Service Summary January 2023 legionella control visit carried out.
 6 monthly temperature checks carried out.
 Annual TMV servicing carried out.
 All other results satisfactory.
Faults Identified Yes
Have Any Fault/s Been Reported More Than 3 Consecutive Times No
Fault Report Ground floor Disabled WC TMV failsafe has failed, please replace the TMV ASAP.

Fault Pictures



Ground floor
 Disabled
 WC TMV

Have work areas been left clean & tidy & any waste bagged & disposed of Yes

Engineer Name Thomas Bryan

Engineer Signature

TB

24/01/2023 09:48

Client Name Julie Hopkins

From
 B6 "urgent"
 (Screw fix)
 £54)

Handwritten mark